



Burlington, WA Corporate Laboratory (a)
1620 S Walnut St - Burlington, WA 98233 - 800.755.9295 - 360.757.1400
Bellingham, WA Microbiology (b)
805 Orchard Dr Ste 4 - Bellingham, WA 98225 - 360.715.1212

Portland, OR Microbiology/Chemistry (c)
9150 SW Pioneer Ct Ste W - Wilsonville, OR 97070 - 503.682.7802
Corvallis, OR Microbiology/Chemistry (d)
1100 NE Circle Blvd, Ste 130 - Corvallis, OR 97330 - 541.753.4346
Bend, OR Microbiology (e)
20332 Empire Blvd Ste 4 - Bend, OR 97701 - 541.639.8425




Washington State Department of Health WATER BACTERIOLOGICAL ANALYSIS

Client Name: Glenhaven Lakes Club, Inc.
664 Rainbow Dr
Sedro Woolley, WA 98284

Reference Number: 21-40557
Project: Glenhaven Lakes Club Bacteria

System Name: GLENHAVEN LAKES CLUB
System ID Number: 28050V
DOH Source Number: 00 - Distribution Sample (Bacteria)
Sample Type: D - Drinking Water
Sample Purpose: C - Compliance
Sample Location: X2 - Summit PI
County: Whatcom
Sampled By: Michael Gallagher
Sampler Phone: 360-595-2061

Repeat Sample Number:
Lab Number: 164-78104
Field ID: Glenhaven Lakes
Date Collected: 10/25/21 09:05
Date Received: 10/25/21
Date Set: 10/25/21 11:46
Date Analyzed: 10/26/21 9:36
Report Date: 10/27/21
Comment:
Approved By: clh,rml

Authorized by: 
Ceann K Knox
Lab Manager, Bellingham

DOH#	PARAMETER	RESULT	Qualifier	UNITS	Analyst	METHOD	Batch	COMMENT
1	TOTAL COLIFORM	Satisfactory, Coliforms Absent		per 100mL	jln	SM9223 B	m_211025a	
3	E. COLI	Absent		per 100mL		SM9223 B	m_211025a	

If the sample is unsatisfactory you can get information at the following health department websites or phone numbers:

- Island Co: <http://www.islandcounty.net/health/Envh/DrinkingWater/index.htm>
- San Juan Co: <http://www.sanjuanco.com/health/ehswater.aspx>
- Skagit Co: <http://www.skagitcounty.net/drinkingwater> or 360-336-9380
- Snohomish Co: 425-339-5250
- Whatcom Co: http://www.co.whatcom.wa.us/health/environmental/drinking_water/index.jsp
- WSDOH: <http://www.doh.wa.gov/ehp/dw/Programs/coliform.htm>

NOTES:
If the result is Unsatisfactory, three (3) repeat samples and groundwater source samples are required for Group A Public Water Systems. Private individuals should investigate the cause of the unsatisfactory result and resample.
If E. Coli or Fecal Coliform are present in sample do not drink the water until it is properly treated.
*If data qualifiers are present, see accompanying Qualifier Definition report.